


कार्यालय अधिशासी अभियन्ता, ग्रामीण अभियन्त्रण विभाग, प्रखण्ड-एटा।


पत्रांक:- 745 / ग्रा0अ0वि0 / संगणक / स्कूल / प्रमाण पत्र / 2019-20


दिनांक- 19/9/19

प्रमाण पत्र

सेण्ट पॉल्स स्कूल, किला रोड अवागढ़ के प्रबन्धक द्वारा प्रस्तुत उक्त स्कूल के निर्माण आदि से सम्बन्धित प्रपत्रों के आधार एवं स्थलीय निरीक्षण के आधार पर प्रमाणित किया जाता है, कि सेन्ट पॉल्स स्कूल, किला रोड, अवागढ़, एटा का भवन नेशनल बिल्डिंग कोड 2005 के मानकों के अनुसार निर्मित है, तथा भवन सुरक्षित है।



अवर अभियन्ता
ग्रामीण अभियन्त्रण विभाग,
एटा।


सहायक अभियन्ता
ग्रामीण अभियन्त्रण विभाग,
एटा।


अधिशासी अभियन्ता,
ग्रामीण अभियन्त्रण विभाग,
एटा।

पत्रांक एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि- प्रबन्धक, सेन्ट पॉल्स सीनियर सेकेन्ड्री स्कूल, निधौली रोड एटा को उनके पत्र दिनांक 16-09-2019 के क्रम में प्रेषित।


अधिशासी अभियन्ता,
ग्रामीण अभियन्त्रण विभाग,
प्रखण्ड-एटा।

GURU PRASAD

B.Tech. & M.Tech. (IIT/K); C.Eng(I), MIE, LM-QCI

Chartered Engineer

54-Nehru Nagar , Agra - 282 002 , India

Tel / Fax (0562) 2520140

Email: gpgupta48@yahoo.co.in

Ref. No. GP/Inspection/St.Paul's-Etah-3
Date 30-07-2019**Inspection Report - Building Safety**

Inspection of: St. Paul's School, Fort Road, Awagarh, Etah

Terms of reference: To assess the fitness of school building with reference to safety for occupation.

Pursuant to the request, the school building was inspected on 30-7-2019 to assess its condition from structural fitness point of view. The detailed visual examination of each vital element (columns, walls, roof beams, roof slab and water proofing of roof) of the building was done and nothing adverse was seen to give the impression of building not being structurally fit. The investigation was also guided by Rebound Hammer Tests and Ultrasonic Pulse Velocity Tests in accordance with IS:13311 - 1992 (Part 1 and 2).

The overall condition of the building was good. The same can be seen from the photograph attached.

In the opinion of the undersigned the building is structurally fit to serve its purpose - operating as a school building.

Place: Agra

Date: 01-08-2018

GURU PRASAD
B.Tech. & M.Tech. (IIT/K), Civil Eng.(I), M.I.E., M.I.G.S.
Chartered Engineer
54, Nehru Nagar, AGRA-282002
Ph. : (0562) 2855093, 2520140

